

**Session:** The way forward for reliable operation of the power system with high variable renewables penetration in the Indian grid

**R. K. Porwal, Director (System Operation)**  
Grid Controller of India Ltd.





Source: GO15

- 1** national synchronous grid
- electricity generation
- 3** electricity consumption
- installed generation capacity
- transmission system
- 4** wind generation
- solar generation
- 6** hydro generation
- 10** pumped storage capacity

Renewable Capacity Addition > 13% CAGR since 2017

# Dimensions of Indian Power System






\* Till Mar 2024  
Source: CEA Installed Capacity Report (data as on Apr 2024)  
<https://cea.nic.in/installed-capacity-report/?lang=en>

**Highest Instantaneous RE penetration of ~32.4% recorded on 14<sup>th</sup> July 2023**

**Maximum Wind + Solar penetration in instantaneous MW and energy (day/year) terms – FY 2023-24**



**~11% all India VRE penetration on annual basis**





ALL INDIA INSTALLED CAPACITY (MW)			
Resource	March 2024	March 2030	% Addition
Hydro (including PSP)	46928	59210	26%
Small Hydro	5003	18986	279%
Solar PV	81813	292566	258%
Wind	45887	99895	118%
Biomass	10940	14500	33%
Nuclear	8180	15480	89%
Coal+Lignite	218178	251683	15%
Gas	25038	25038	0%
<b>Total</b>	<b>441967</b>	<b>777358</b>	<b>76%</b>
<b>BESS</b>	0	41650 (5-hr)	

Source: CEA Report On Optimal Generation Capacity Mix for 2030 (Ver 2.0)

# As on Mar 2024 as per Operational Data of Grid-India

\* As on Mar 2024 from CEA Installed Capacity Report



^ 20<sup>th</sup> EPS Survey by CEA

	April 2024	Mar 2030
 <b>Maximum Demand Met (GW)</b>	~240 <sup>#</sup>	334 <sup>^</sup>
 <b>Total Generation Installed Capacity (GW)</b>	442 <sup>*</sup>	777
 <b>Non-fossil Fuel Based Generation Installed Capacity (GW)</b>	199 <sup>*</sup>	500
 <b>Wind &amp; Solar Installed Capacity (GW)</b>	127 <sup>*</sup>	393

## Major Operational and Planning Challenges


1. Renewable integration in India unique in terms of concentrated capacity addition in close vicinity (Rajasthan RE Complex SLD)
2. Possibility of large disturbance/generation loss in case of any non-compliance
3. Challenges in ensuring sufficient system strength in remotely located RE pockets
  - Large variation in steady-state voltages due to low system strength
  - Transient voltage overshoot during switching operation leading to HVRT conditions
4. Lack of Black Start sources in remote RE pockets

6000 MW RE Generation Loss on 11<sup>th</sup> Aug 2022



## Major Operational and Planning Challenges

5. Power quality issues due to large number of converter based devices
6. Low gestation period of renewables vis-à-vis transmission
7. Behavioral change in corridor power flows
8. Resource Adequacy concerns especially in low renewable generation periods
9. Increasing ramping requirement and lack of commensurate flexible generating resources
10. Renewable forecasting accuracy related challenges



Increasing “Duck Curve” Belly !!

1. Comprehensive set of regulations and standards governing interconnection and operations of the renewable plants
  
2. Robust Compliance Verification Process
  - Established procedures for technical data and reports submission
  - Commencement of compliance verification process at least 01 year before physical interconnection of the plant
  - Independent compliance verification by both system planner and operator
  - Widespread synchro-phasor initiative to assist in post-commissioning performance validation and event analysis
  
3. Perspective transmission planning on a rolling basis - based on potential RE zones - to ensure timely availability of transmission (details)
  
4. Planning and deployment of innovative solutions for Grid Stability – VSC based HVDCs, Storage, FACTS Devices, Synchronous Condensers etc.



5. Comprehensive regulatory framework for ensuring Short and Long term Resource Adequacy
  
6. Thermal Flexibility Initiatives (details)
  - Pilot projects on Thermal Flexibilization
  - Phasing Plan for Implementation of 40% Technical Minimum Level in Coal-fired plants
  - Incentive for providing higher ramp rates
  
7. Dedicated Renewable Energy Management Centers (co-located with LDCs) for dedicated monitoring, forecasting and scheduling of solar and wind plants

- 1. Regular strengthening of regulations and standards governing grid operations and renewable interconnection to keep with the evolving grid requirements**
  - Enabling provisions for model data submission and validation
  - Enabling provisions for high resolution data recording at IBR level for facilitating post event analysis
  - Black Start Capability / Grid Forming Capability of Inverters
- 2. Periodic consultation/workshops with stakeholders (plant developers, equipment manufacturers etc.) for mutual knowledge sharing and capacity building**
- 3. Identifying and periodically reviewing the right resource mix for medium and long-term duly factoring in resource adequacy and flexibility requirements**
- 4. Flexibility Initiatives – Requisite changes in regulations; Valuing hydro flexibility etc.**



# ERRA

21<sup>st</sup> Annual Conference  
ENERGY REGULATORS FORUM

CO-LOCATED WITH FGA

## Adaptive Regulation in Energy Transition

15 - 17 MAY 2024 | Bangkok, Thailand

# Thank You


Organised By




Hosted By



Energy Regulatory Commission  
Office of the Energy Regulatory Commission




## Fault MVA at EHV level



**Challenges in ensuring sufficient system strength in remotely located RE pockets**

[Back](#)

Reduction in SCR due to depleted network




Switching of 240 MVAR Line reactor


- Depleted network before event
- 32 kV Voltage rise in phase to neutral
- EHV Lines tripped on Overvoltage
- Triggered HVRT and consequent loss of 2000 MW generation

Large change in voltages during switching of network elements


Transient voltage rise leading to tripping of EHV lines and Renewable plants on overvoltage



Several incidents of RE generation loss due to large voltage fluctuations during switching operations




NR Import




SR Import

**Bi-directional Flows  
The New Normal !!**




WR - NR




WR - SR

- Resource Adequacy Challenges due to the variability of RE
- Reserve requirements and system constraints would also vary

[Back](#)





**Highest Instantaneous RE penetration (in 23-24) of ~32.4% was recorded on 14<sup>th</sup> July 2023**



**Low RE penetration during High Demand Season - 31<sup>st</sup> August 2023**



[Back](#)




**All India Demand**  
Typical Ramp rate ~ 250-300 MW/min  
Special Days ~ 500 MW/min

Change in Load Shape


Increasing uncertainty on demand side

Near Future –  
EV Charging?  
Induction Cooking?

Combined(Wind & Solar) NRMSE REV\_16



$$\square \text{NRMSE} = \frac{1}{n} \sum_{1}^n \sqrt{\left(\frac{\text{Act} - \text{Forecast}}{\text{AvC}}\right)^2}$$



Approx. 8000 MW reduction in solar generation in 1 hour due to Cloud Cover

Forecast Accuracy



Key to Renewable Integration

## 1. Central Electricity Authority (CEA), Technical Standards for Connectivity to the Grid Regulations, 2007 and subsequent amendments




- Low and High Voltage Ride Through Requirements (LVRT/HVRT)
- Reactive Power Capability
- Dynamic Reactive Power Support
- Active Power and Frequency Control
- Power Quality Requirements

## 2. Central Electricity Regulatory Commission (CERC), Indian Electricity Grid Code, 2023

- Trial run operation of wind, solar and BESS
- Frequency response from RE plants
- Periodic testing of RE plants

## 3. Other Regulations - Central Electricity Authority's

- Flexible Operation of Coal based Thermal Power Generating Units Regulations, 2023
- Technical Standards for Construction of Electrical Plants and Electric Lines Regulations, 2022
- Grid Standards Regulations, 2010
- Technical Standards for Communication System in Power System Operation Regulations, 2020





[Back](#)

Detailed requirements specified in Grid-India's procedure for "First-Time Energization of New and Modified Elements"



- **Perspective Planning - Central Electricity Authority's report on Transmission Plan for 500 GW RE by 2030**
- **Recognition of Low Gestation Period of RE and BESS vis-à-vis Transmission**
  - Fast tracking of approvals of transmission schemes through empowerment of system planner (CTUIL)
  - **Short-term transmission plan** every year on a rolling basis for the next 5 years
  - **Perspective transmission plan** every alternative year on a rolling basis for the next 10 years
  - **Implementation plan for inter-state transmission system** every year on a rolling basis for up to the next 5 years
- **Implementation of CERC's General Network Access Regulations w.e.f. 1<sup>st</sup> Oct 2023**



**Innovative Solutions for Grid Stability – VSC Based HVDC, RE + Storage, FACTS Devices, Synchronous Condensers etc.**

## 1. Regulatory Framework for Long and Short-term Resource Adequacy Studies

- Electricity (Amendment) Rules, 2022 notified by the Government of India, Ministry of Power
- Indian Electricity Grid Code, 2023 notified by the Central Electricity Regulatory Commission
- CEA - Guidelines for Resource Adequacy

## 2. Other Initiatives w.r.t. Resource Adequacy


- Shifting of load to high generation (solar) period
- Notifying trajectory for Storage
- Pilot project on 4000 MWhr grid scale Battery Energy Storage

## 1. CEA (Flexible Operation of Coal based Thermal Power Generating Units) Regulations, 2023



- Specified **Minimum Power Level of 40% for Thermal Generating Units**
- Requires thermal generators to be capable of providing **1%–3% ramp rate**

## 2. CERC (Terms and Conditions of Tariff) Regulations, 2019

- Incentivized generators to provide ramping capability beyond the threshold of 1% and to penalize in case of failure to provide 1%, in terms of return on equity
  - rate of return on equity shall be **reduced by 0.25%** in case of failure to achieve the ramp rate of 1% per minute;
  - an **additional rate of return on equity of 0.25%** shall be allowed for every incremental ramp rate of 1% per minute achieved over and above the ramp rate of 1% per minute, subject to ceiling of additional rate of return on equity of 1.00%







## Renewable Energy Management Centers

- Co-located with the Load Despatch Centers at 12 locations
- One Energy Management Centre at Andaman and Nicobar Islands.
- **106 GW Wind and Solar Capacity monitored**
- **1490 Pooling stations**
- **79 GW scheduled at Intra-state level**
- **27 GW Scheduled at Inter-state level**
- **Facilities**
  - Day ahead/intra-day forecasting, scheduling
  - Telemetry
  - Analog : P, Q, V, Weather
  - Status: Transmission, Inverter / WTG

## Frequency Support



- Increasing Rate of Change of Frequency (RoCoF)
- Decreasing nadir frequency
- Excessive frequency deviations

## Voltage Support



- Static reactive power balance
- Dynamic reactive power balance
- Larger voltage dips

## New Behavior of the Power System



- Fault ride through failures
- Decreased damping
- Oscillations
- Control of bi-directional flows
- Lack of power system restoration sources

Bulk of essential reliability services such as inertia, frequency, and voltage control, system restoration support, power oscillation damping, short-circuit power, etc. were being provided by conventional generation sources

**Renewables + Transmission (FACTS + HVDCs)** to play a critical role in providing the necessary support in the new regime